

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID#399073400

Client: MacNeil Environmental Inc
 Grygla Schools
Address: 112 Northwest 5th Street
 Grand Rapids, MN 55744

Report Number: 16-17085
Sample Collection Date: 11/08/16
Sample Collection Time: 6:50
Sample Receipt Date: 11/22/16

Twin City Water Clinic Inc.
 617 13th Avenue South
 Hopkins, MN 55343
 Phone: (952)935-3556

X No samples were subcontracted, or the above test result(s) with "*" designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

| Laboratory Sample ID | Analyte | Sample Location | Parameter | Sample Date | Sample Time | Sample Date | Sample Time | Test Results | Units |
|----------------------|---------|---------------------|----------------|-------------|-------------|-------------|-------------|--------------|-------|
| 16-17085 | Lead | Civic Bid | Drinking Water | 11/22/16 | 14:00 | 12/02/16 | 11:46 | 3.81 | µg/L |
| 16-17086 | Lead | Elementary Fountain | Drinking Water | 11/22/16 | 14:00 | 12/02/16 | 11:50 | <2.0 | µg/L |
| 16-17087 | Lead | Lobby Fountain | Drinking Water | 11/22/16 | 14:00 | 12/02/16 | 11:55 | <2.0 | µg/L |
| 16-17088 | Lead | Laundry Fountain | Drinking Water | 11/22/16 | 14:00 | 12/02/16 | 12:49 | <2.0 | µg/L |
| 16-17089 | Lead | Kitchen | Drinking Water | 11/22/16 | 14:00 | 12/02/16 | 13:02 | 5.14 | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |
| | Lead | | Drinking Water | | | | | | µg/L |

Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant levels: Lead, 15.0 µg / L

Sample Collected by: Client TCWC

Approved By:

[Signature]
 Laboratory Manager

Senior Analyst

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.